

***Annual Drinking Water Quality Report
for 2009
Village of Elmsford Water Department
15 S. Stone Avenue
Elmsford, New York 10523
Public Water Supply ID# 5903427***

INTRODUCTION

To comply with State regulations, the Village of Elmsford Water Department issues an annual report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact the Village Engineer's office at 345-1553. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. The meetings are held on Monday evenings at 7:30 PM and are announced in the newspaper, the Village Cable TV Station, the Village Web Page and posted at Village Hall.

Information for Non-English Speaking Residents

Espanol - Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The Village purchases its water supply from the City of New York, Department of Environmental Protection (NYCDEP), Bureau of Water Supply. Partially treated

water is supplied from a connection to the Catskill Aqueduct. The water originates in a protected watershed area 100 miles northwest of Elmsford in the Catskill Mountains where New York City has constructed 6 large reservoirs that together have the capacity of 473.4 billion gallons of water. This entire system consists of 17 reservoirs in three watershed areas (Delaware, Catskill, Croton), which allows maximum flexibility in delivering the highest quality of water possible. The entire New York City reservoir system has the ability to deliver a maximum of 1.45 billion gallons per day. The Catskill & Delaware waters normally mix in the Kensico Reservoir located in the town of Mount Pleasant. This "blending" of the water upstream of our point of withdrawal enhances the overall water quality. Kensico Reservoir also acts as a large settling basin due to the twenty to thirty day retention time it takes water to travel through the reservoir. During this time, any natural organic materials measured as "turbidity" that seasonally occurs from spring run-off and heavy rains upstate, settle out in the large reservoir thereby clarifying the water. The Catskill/Delaware raw water quality, south of the Kensico Reservoir, is of such high quality that the Federal Environmental Protection Agency and the New York State Health Department have given a filtration waiver to communities relying on this water. The Catskill water north of the Kensico Reservoir, due to the seasonal "turbidity events" and the Croton system, due to deteriorated quality, must both be filtered to meet federal and state requirements. This explains why some Northern Westchester districts and Hudson River communities must filter their water. Since Elmsford takes its water after it has had the advantage of the above-described natural treatment, the quality meets all regulatory requirements and needs only minimal additional treatment for disinfection purposes. During 2009, our system did not experience any restriction of our water source.

FACTS AND FIGURES

Our water system serves approximately 4,676 people (based on 2000 census figures) through 1199 service connections. The total water produced in 2009 was 228 million gallons; another 0.9 million gallons was purchased from the Town of Greenburgh during periods when the Catskill Aqueduct was shut down for maintenance by the City of New York. Greenburgh also purchases water from the City of New York, through a separate aqueduct.

The daily average of water treated and pumped into the distribution system was 625,000 gallons. The amount of water delivered to customers for the year was 171 million gallons. When subtracted from the amount of water produced, this leaves an un-metered total of 57 million gallons or 25% of the total amount produced. This water was used to flush mains to improve water quality, test fire hydrants, fight fires and lost through leakage. In 2009, water customers were charged \$6.35 per 1,000 gallons of water; commercial users were charged a stepped rate beginning at \$ 6.60 per 1,000 gallons for the first 100,000 gallons used and topping off at \$ 8.10 per 1,000 gallons from 500,001 gallons and above.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

The State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change

frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Westchester County Health Department at 813-5000.

Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Average) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Sources of Contamination
TTHM (Chloroform, Bromodichloromethane, Dichloromethane, And bromoform) ⁴	no	8/7/09	36.88	ug/L	N/A	80	By-product of drinking water Chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter
Haloacetic Acid ⁴	no	4/28/09	32.8	ug/L	N/A	60	By-product of drinking water Chlorination.
Turbidity ¹	no	4/21/09	2.2 0.88 avg.	NTU	N/A	5	Soil Runoff
Barium	no	1/27/09	16.8	ug/L	2,000	2,000	Naturally occurring
Chloride	no	1/27/09	9.75	mg/L	N/A	250	Naturally occurring or indicative of road salt contamination
Sodium	no	1/27/09	5.44	mg/L	N/A	20	Naturally occurring; Road salt; Water Softeners; Animal Waste.
Manganese	no	1/27/09	12.6	ug/l	N/A	300	Naturally occurring, indicative of landfill contamination
Magnesium	no	1/27/09	1250	ug/l	N/A	N/A	Naturally occurring
Nitrate	no	1/27/09	0.222	mg/l	N/A	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Flouride	no	1/27/09	0.807	ug/l	N/A	2.2	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	no	1/27/09	25.6	ug/l	N/A	300	Naturally occurring
Total Dissolved Solids	no	1/27/09	46	mg/l	N/A	N/A	Naturally occurring
Copper ²	no	7/21/09 to 8/6/09	267 34.4 – 343	ug/l	N/A	AL – 1,300	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives
Lead ³	no	7/21/09 to 8/6/09	8.0 ND – 33.4	ug/l	0	AL – 15	Corrosion of household plumbing systems; Erosion of natural deposits
Radium 226 & 228	no	1/27/09	1.00	pCi/l	N/A	5	Erosion of natural deposits

Notes:

1 – Turbidity is a measure of the cloudiness of the water. Our highest single turbidity measurement (2.2 NTU) for the year occurred on April 21. State regulations require that turbidity must always be below 5 NTU.

2 – The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90th percentile value was the second highest value (267 mg/l). The action level for copper was not exceeded at any of the sites tested.

3 – The level presented represents the 90th percentile of the 20 samples collected. The action level for lead was exceeded at one of the 20 sites tested.

4 – This level represents the annual quarterly average calculated from data collected.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

INFORMATION ON LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Village of Elmsford Water Department is responsible for

providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2009, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

INFORMATION ON CRYPTOSPORIDIUM

Cryptosporidium is a microbial pathogen found in surface water and groundwater under the influence of surface water. During 2009, as part of their routine sampling, the NYCDEP collected a total of 52 samples from the Catskill Aqueduct at the Kensico Reservoir water supply (one per week) and analyzed them for Cryptosporidium oocysts. The samples were taken prior to chlorination. Of these samples, one was positive for Cryptosporidium. Therefore, testing indicates the presence of Cryptosporidium in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Cryptosporidium may cause cryptosporidiosis, a gastrointestinal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their health care provider regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

INFORMATION ON GIARDIA

Giardia is a microbial pathogen present in varying concentrations in many surface waters and groundwater under the influence of surface water. Giardia is removed/inactivated through a combination of filtration and disinfection or by disinfection. During 2009, as part of their routine sampling, the NYCDEP collected a total of 52 samples from the Catskill Aqueduct at the Kensico Reservoir water supply (one per week) and analyzed them for Giardia cysts. The samples were taken prior to chlorination. Of these samples, 44 were positive for Giardia. Therefore, testing indicates the presence of Giardia in our in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Giardia may cause giardiasis, an intestinal illness. People exposed to Giardia may experience mild or severe diarrhea, or in some instances no symptoms at all. Fever is rarely present. Occasionally, some individuals will have chronic diarrhea over several weeks or a month, with significant weight loss. Giardiasis

can be treated with anti-parasitic medication. Individuals with weakened immune systems should consult with their health care providers about what steps would best reduce their risks of becoming infected with Giardiasis. Individuals who think that they may have been exposed to Giardiasis should contact their health care providers immediately. The Giardia parasite is passed in the feces of an infected person or animal and may contaminate water or food. Person to person transmission may also occur in day care centers or other settings where handwashing practices are poor.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. Fluoride is added to your water by the NYCDEP before it is delivered to us. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.8 to 1.2 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that the NYCDEP monitor fluoride levels on a daily basis. During 2009 monitoring showed fluoride levels in your water were in the optimal range approximately 99 % of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day (6,000 gallons/yr)
- ♦ Check your toilets for leaks. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save over 30,000 gallons a year. Check your toilets for leaks by adding a few drops of food coloring in the tank and watch for a few minutes to see if the color shows up in the bowl.
- ♦ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes, if it moved, you have a leak.

SYSTEM IMPROVEMENTS

In 2009 the Village continued replacing fire hydrants. A total of 4 hydrants were replaced and two were repaired. The Village is also completing the replacement of all water meters with newer models that can be read by a portable handheld scanner and downloaded to a computer for billing. This provides for more accurate and efficient meter reading. If your meter has not yet been replaced, contact the Village of Elmsford Water Department immediately at 592-7770 to make an appointment.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call the Village Engineer's office – 345-1553 if you have questions.

STORM WATER POLLUTION PREVENTION

What is Storm Water?

Storm water is water from precipitation that flows across the ground and pavement when it rains or when snow and ice melt. The water seeps into the ground or drains into what we call storm sewers. You see these drains at street corners or at low points on the sides of your streets.

Where does the Storm Water go after it drains into a Storm Drain? Storm water that does not seep into the ground drains into systems of underground pipes or open swales and eventually discharges into the Saw Mill River or the Bronx River. This storm water eventually ends up in the Hudson River and/or Long Island Sound.

Did You Know: Substances that enter storm drain inlets in the streets cannot be removed or treated before entering our rivers and the Long Island Sound?

Those substances that enter the storm drain system are not treated at all! Anything poured into a gutter or a storm drain, such as used motor oil or antifreeze, pet waste and debris, flows directly to the Rivers and Long Island Sound, usually via neighborhood storm sewers.

What are Common Contributors to Storm Water Pollution? When it rains, oil, antifreeze, detergents, pesticides, pet waste and other pollutants get washed from driveways, backyards, parking lots, and streets into storm drains and then directly to the Rivers untreated!

Spread the word about protecting our rivers, tell your neighbors. For more information, contact the Village.